


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°

DATA OF LAMP		PHOTOMETRIC DATA Eff: 41.03 lm/W			
MODEL	6796	I _{max} (cd)	3822	S/MH(C0/180)	0.39
NOMINAL POWER(W)	20	LOR(%)	100.0	S/MH(C90/270)	0.39
RATED VOLTAGE(V)	85-265V	TOTAL FLUX(lm)	823.99	h UP, DN(C0-180)	0.0,50.2
NOMINAL FLUX(lm)	823.988	CIE CLASS	DIRECT	h UP, DN(C180-360)	0.0,49.8
LAMPS INSIDE	1	h up(%)	0.0	CIBSE SHR NOM	0.00
TEST VOLTAGE(V)	220	h down(%)	100.0	CIBSE SHR MAX	1.00

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



H_b Range: -90 - 90DEG
H_b Interval: 1.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2026-07-02

V(B) Range: -75 - 75DEG
V(B) Interval: 5.0DEG
Test System: EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity: 65.0%
Test Distance: 5.000m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

g	C0	C45	C90	C135	C180	C225	C270	C315	g	F zone	F total	%lum, lamp
10	2579	2375	2171	1823	2263	1833	2187	2381	0- 10	263.6	263.6	32, 32
20	664.2	799.4	924.5	424.4	506.5	430.7	935.1	796.3	10- 20	353.5	617.1	74.9, 74.9
30	65.50	144.3	72.22	85.92	53.19	85.46	56.36	137.1	20- 30	148.7	765.8	92.9, 92.9
40	19.55	17.63	35.13	17.33	23.04	18.09	27.99	17.38	30- 40	26.18	791.9	96.1, 96.1
50	12.48	10.46	14.61	11.07	14.97	10.91	12.13	10.01	40- 50	12.01	803.9	97.6, 97.6
60	8.682	7.249	10.66	7.819	10.20	7.437	8.780	6.896	50- 60	8.835	812.8	98.6, 98.6
70	5.465	5.103	6.420	5.334	6.265	5.074	5.889	4.946	60- 70	6.630	819.4	99.4, 99.4
80	3.434	2.243	0	2.109	3.375	2.561	0	2.683	70- 80	3.936	823.3	99.9, 99.9
90	2.105	0	0	0	1.725	0	0	0	80- 90	0.6402	824.0	100, 100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT: lm		

Conical surface Flux(90deg): 798.73 lm

%lum = 96.9%

%lamp = 96.9%

Conical surface Flux(120deg): 812.78 lm

%lum = 98.6%


%lamp = 98.6%

H_(b) Range:-90 - 90DEG
 H_(b) Interval: 1.0DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:
 Test Date:2026-07-02

V(B) Range:-75 - 75DEG
 V(B) Interval: 5.0DEG
 Test System:EVERFINE G0-2000A_V1 SYSTEM V2.00.411
 Humidity:65.0%
 Test Distance:5.000m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°



LUMINANCE cd/(m2)		
G(DEG)	C0/180	C90/270
85	278	0
80	198	0
75	168	165
70	160	188
65	164	202
60	174	213
55	184	220
50	194	227
45	206	234


H_(b) Range: -90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2026-07-02

V(B) Range: -75 - 75DEG
V(B) Interval: 5.0DEG
Test System: EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity: 65.0%
Test Distance: 5.000m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°

r CC	80%			70%			50%			30%			10%			0
r W	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r fc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.12	1.10	1.09	1.10	1.08	1.07	1.06	1.05	1.04	1.03	1.01	1.00	.99	.98	.98	.96
2.0	1.07	1.03	1.01	1.05	1.02	.00	1.02	.99	.97	.99	.97	.95	.96	.95	.93	.92
3.0	1.02	.98	.95	1.00	.97	.94	.98	.95	.93	.96	.93	.91	.93	.91	.90	.88
4.0	.97	.93	.90	.96	.92	.89	.94	.91	.88	.92	.90	.87	.91	.88	.86	.85
5.0	.93	.89	.86	.93	.89	.85	.91	.87	.85	.89	.86	.84	.88	.85	.83	.82
6.0	.90	.86	.82	.89	.85	.82	.88	.84	.82	.87	.84	.81	.86	.83	.81	.79
7.0	.87	.82	.79	.86	.82	.79	.85	.81	.79	.84	.81	.78	.83	.80	.78	.77
8.0	.84	.80	.77	.83	.79	.76	.83	.79	.76	.82	.78	.76	.81	.78	.76	.75
9.0	.81	.77	.74	.81	.77	.74	.80	.76	.74	.79	.76	.74	.79	.76	.73	.72
10.0	.79	.75	.72	.79	.74	.72	.78	.74	.72	.77	.74	.71	.77	.73	.71	.70



H_(b) Range: -90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2026-07-02

V(B) Range: -75 - 75DEG
V(B) Interval: 5.0DEG
Test System: EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity: 65.0%
Test Distance: 5.000m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm								
NAME:			TYPE:			WEIGHT:		
SPEC.:			DIM.: 60*55*297mm			SERIAL No.:01		
MFR.: NORDECOR			SUR.:			Shielding Angle:24°		

r _{cc}	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Wall Exitance Coefficients(WEC)												
0.0																
1.0	.147	.083	.026	.140	.080	.025	.128	.073	.023	.116	.067	.021	.106	.061	.020	
2.0	.136	.075	.023	.131	.072	.022	.120	.067	.021	.111	.062	.019	.102	.058	.018	
3.0	.127	.068	.020	.122	.066	.020	.114	.062	.019	.106	.058	.018	.098	.054	.017	
4.0	.119	.062	.018	.115	.060	.018	.108	.057	.017	.101	.054	.016	.095	.051	.016	
5.0	.112	.057	.017	.108	.056	.016	.102	.053	.016	.096	.051	.015	.091	.049	.015	
6.0	.106	.053	.015	.103	.052	.015	.097	.050	.015	.092	.048	.014	.088	.046	.014	
7.0	.100	.050	.014	.098	.049	.014	.093	.047	.014	.089	.045	.013	.084	.044	.013	
8.0	.095	.047	.013	.093	.046	.013	.089	.044	.013	.085	.043	.012	.082	.042	.012	
9.0	.091	.044	.012	.089	.043	.012	.085	.042	.012	.082	.041	.012	.079	.040	.012	
10.0	.087	.042	.012	.085	.041	.012	.082	.040	.011	.079	.039	.011	.076	.038	.011	

r _{cc}	80%			70%			50%			30%			10%			0
r _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
r _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Ceiling Cavity Exitance Coefficients(CCEC)												
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.169	.158	.147	.145	.135	.127	.099	.093	.088	.057	.054	.051	.018	.017	.016	
2.0	.151	.133	.117	.130	.114	.101	.089	.079	.070	.051	.046	.041	.016	.015	.013	
3.0	.137	.113	.095	.117	.098	.082	.081	.068	.057	.047	.040	.034	.015	.013	.011	
4.0	.125	.098	.078	.107	.085	.068	.074	.059	.048	.043	.035	.028	.014	.011	.009	
5.0	.114	.086	.065	.098	.074	.056	.068	.052	.040	.039	.030	.024	.013	.010	.008	
6.0	.106	.076	.055	.091	.066	.048	.063	.046	.034	.036	.027	.020	.012	.009	.007	
7.0	.098	.068	.047	.084	.059	.041	.058	.041	.029	.034	.024	.017	.011	.008	.006	
8.0	.092	.061	.040	.079	.053	.035	.055	.037	.025	.032	.022	.015	.010	.007	.005	
9.0	.086	.056	.035	.074	.048	.031	.051	.034	.022	.030	.020	.013	.010	.007	.004	
10.0	.081	.051	.031	.070	.044	.027	.049	.031	.019	.028	.018	.011	.009	.006	.004	

H_(b) Range: -90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2026-07-02

V(B) Range: -75 - 75DEG
V(B) Interval: 5.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.411
Humidity: 65.0%
Test Distance: 5.000m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm											
NAME:					TYPE:			WEIGHT:			
SPEC.:					DIM.: 60*55*297mm			SERIAL No.:01			
MFR.: NORDECOR					SUR.:			Shielding Angle:24°			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions	Viewed crosswise					Viewed endwise					
x = 2H y = 2H	-1.5	-0.8	-1.3	-0.6	-0.5	0.3	1.0	0.5	1.2	1.3	
	3H	-0.3	0.4	-0.1	0.5	0.7	1.6	2.3	1.8	2.4	2.6
	4H	0.3	0.9	0.6	1.1	1.3	2.1	2.7	2.4	2.9	3.2
	6H	0.9	1.5	1.2	1.7	2.0	2.2	2.8	2.4	3.0	3.2
	8H	1.2	1.8	1.5	2.0	2.3	2.1	2.7	2.4	2.9	3.2
	12H	1.5	2.1	1.8	2.3	2.6	2.1	2.6	2.4	2.9	3.1
4H	2H	-1.0	-0.4	-0.7	-0.2	0.1	0.6	1.2	0.8	1.4	1.6
	3H	0.3	0.9	0.6	1.1	1.4	2.1	2.6	2.4	2.9	3.2
	4H	1.0	1.5	1.3	1.8	2.1	2.7	3.2	3.1	3.5	3.8
	6H	1.7	2.1	2.0	2.5	2.8	2.8	3.2	3.2	3.6	3.9
	8H	2.0	2.4	2.4	2.8	3.1	2.8	3.2	3.1	3.5	3.9
	12H	2.4	2.8	2.8	3.1	3.5	2.7	3.1	3.1	3.4	3.8
8H	4H	1.3	1.8	1.7	2.1	2.5	2.9	3.3	3.2	3.6	4.0
	6H	2.2	2.5	2.6	2.9	3.3	3.0	3.3	3.4	3.7	4.1
	8H	2.6	2.9	3.1	3.3	3.8	2.9	3.2	3.4	3.6	4.1
	12H	3.1	3.3	3.5	3.8	4.3	2.9	3.1	3.3	3.6	4.0
12H	4H	1.3	1.7	1.7	2.1	2.5	2.9	3.2	3.3	3.6	4.0
	6H	2.2	2.5	2.6	2.9	3.3	3.0	3.3	3.4	3.7	4.1
	8H	2.6	2.9	3.1	3.3	3.8	2.9	3.2	3.4	3.6	4.1
Variations with the observer position at spacings:											
S = 1.0H	+ 0.3 / - 0.3					+ 0.6 / - 0.7					
1.5H	+ 0.5 / - 0.5					+ 1.6 / - 0.6					
2.0H	+ 0.8 / - 1.0					+ 0.5 / - 0.9					

CIE Pub.117, 824.0 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -0.7)
Area: 0.1 m2

H_(b) Range:-90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2026-07-02

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity:65.0%
Test Distance:5.000m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	89	83	80	89	83	79	88	83	79	76
0.80	96	91	87	96	90	87	94	90	87	83
1.00	100	95	92	99	95	91	98	94	91	87
1.25	104	99	96	103	98	95	101	97	95	91
1.50	107	102	99	105	101	98	103	100	97	93
2.00	109	105	102	108	104	101	105	102	100	95
2.50	111	107	104	109	106	103	106	103	101	95
3.00	112	109	106	110	107	105	107	105	103	97
4.00	114	111	109	112	110	108	108	107	105	98
5.00	115	113	111	113	111	110	109	108	107	99
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

H_b Range:-90 - 90DEG
H_b Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2026-07-02

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity:65.0%
Test Distance:5.000m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°




H_(b) Range:-90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2026-07-02

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity:65.0%
Test Distance:5.000m [K=1.0000]
Remarks:

AAI Figure

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

H_(b) Range:-90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2026-07-02

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity:65.0%
Test Distance:5.000m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°



H_(b) Range: -90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2026-07-02

V(B) Range: -75 - 75DEG
V(B) Interval: 5.0DEG
Test System: EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity: 65.0%
Test Distance: 5.000m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:220.24V I:0.1958A P:20.080W PF:0.4657 Freq:50.00Hz Lamp Flux:823.988x1 lm		
NAME:	TYPE:	WEIGHT:
SPEC.:	DIM.: 60*55*297mm	SERIAL No.:01
MFR.: NORDECOR	SUR.:	Shielding Angle:24°


AvgL	cd/m2
L_0~180(65)av	177
L_0~180(75)av	175
L_0~180(85)av	270
L_90~270(65)av	188
L_90~270(75)av	169
L_90~270(85)av	0
L_45(65)av	148
L_45(75)av	152
L_45(85)av	0

Standard: GB/T 29293-2012

H_(b) Range:-90 - 90DEG
H_(b) Interval: 1.0DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:
Test Date:2026-07-02

V(B) Range:-75 - 75DEG
V(B) Interval: 5.0DEG
Test System:EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity:65.0%
Test Distance:5.000m [K=1.0000]
Remarks:

Planar Illuminance Curve



H_b Range: -90 - 90DEG
H_b Interval: 1.0DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators:
Test Date: 2026-07-02

V(B) Range: -75 - 75DEG
V(B) Interval: 5.0DEG
Test System: EVERFINE G0-2000A_V1 SYSTEM V2.00.411
Humidity: 65.0%
Test Distance: 5.000m [K=1.0000]
Remarks:

